



**Anne Arundel County
Department of Public Works
Bureau of Utility Operations
COLLECTION SYSTEM DISCHARGE REPORT**

Report Prepared By **LARRY PARSONS**
(Name)

UTILITY LINE SUPERINTENDENT
(Title)

Report ID **808**

Date\Time SSO Discovered **04/17/2019 4:25 PM**

Duration of Discharge **5 HOUR(S)**

Date \ Time SSO Response Initiated **04/17/2019 4:40 PM**

Initial Overflow Volume **1,500** Gallons
Overflow Volume Recovered **100** Gallons
Net Overflow Volume **1,400** Gallons

Estimated ☒ Measured ☐

Type of Facility **SEWER MANHOLE** Facility Name\Number **11218**

Service Area **BROADNECK**

Address **609** Street **PARK PL**

Community **DRUM POINT**

Zip Code **20751**

Latitude **38.78034**

Longitude **-76.55682**

ADC Map\Grid

NPDES Permit Violation ? Yes ☒ No ☐

Identify any Body of Water Impacted by SSO **ROCKHOLD CREEK**

Additional Location
Information (if
required):

Cause of Overflow **SEWER BLOCKAGE**

Was Media Contacted ? Yes ☐ No ☒ Please List:

The Following Agencies were Notified: Emergency Dispatch, State Health Dept., County Health Dept., County Executive's Office, Director - DPW, Maryland Department of the Environment, Deputy Director - DPW

Additional Information
about Cause of SSO

BLOCKAGE FOUND IN SEGMENT 11231- 11229. SPECIFIC LOCATION WAS 217' FROM SMH11231. DIRT AND ROCKS FOUND IN THE LINE AND ON THE BENCH OF SMH 11229.

Measures Taken to
Minimize Impact

RESIDUAL LIQUID VACUUMED, LIME SPREAD, SIGN POSTED

Actions Taken to
Prevent
Reoccurrence

FOLLOW UP LINE WASHING AND CCTV SCHEDULED

NOTE: Follow Policy and Procedure for telephone reporting and follow-up reports

cc: Sharon Talley, MDE
K. Topovski, MS 3101
County Executive, MS 1406
Chief Administrative Officer, MS 1405
Director, DPW, MS 7400
Deputy Director, BUO, MS 4285
Community Services, MS 1408
Emergency Services, MS 4293
Customer Relations, MS 7400

Utility Administrator, WW, MS 4325
Matt Diehl, MS 7400
Ginger Ellis, MS 7409
File

Larry M. Parsons Jr
Superintendent Name (Please Print)

Larry Parsons Jr 4/18/19
Superintendent Signature \ Date

Chris Sh 4/18/19
Utility Operations Administrator Signature \ Date

Phone (410)222-7500